

Village of Rantoul

Copper & Lead Tests Abram Drive

Maximum Containment Level:

Copper = 1300 ug/L

Lead = 15 ug/L

***2014 Aerial Image provided by
Champaign County GIS Consortium



Village of Rantoul
Public Works Dept.
200 W. Grove Avenue
Rantoul, IL 61866
(217) 892-2178



07/20/2016

NOTE: This product was prepared for informational
and general reference purposes. The Village of Rantoul
shall assume no liability for any error, omissions, or
inaccuracies in the information provided.

1429 Abram		
Year	Copper (ug/L)	Lead (ug/L)
2014	41	1
2011	49	1
2008	N/A	N/A

1412 Abram		
Year	Copper (ug/L)	Lead (ug/L)
2014	N/A	N/A
2011	62	1
2008	71	1

1394 Abram		
Year	Copper (ug/L)	Lead (ug/L)
2014	N/A	N/A
2011	N/A	N/A
2008	3	1

1318 Abram		
Year	Copper (ug/L)	Lead (ug/L)
2014	N/A	N/A
2011	N/A	N/A
2008	240	1

1330 Abram		
Year	Copper (ug/L)	Lead (ug/L)
2014	80	1
2011	49	1
2008	190	1

1421 Abram		
Year	Copper (ug/L)	Lead (ug/L)
2014	43	1
2011	110	1
2008	N/A	N/A

1403 Collier		
Year	Copper (ug/L)	Lead (ug/L)
2014	30	1
2011	N/A	N/A
2008	12	1

1400 Bihler		
Year	Copper (ug/L)	Lead (ug/L)
2014	130	1
2011	50	1
2008	N/A	N/A

