

Village of Rantoul

Copper & Lead Tests Indian Hills


Maximum Containment Level:

Copper = 1300 ug/L

Lead = 15 ug/L

***2014 Aerial Image provided by
Champaign County GIS Consortium

0 75 150 300 450 Feet



Village of Rantoul
Public Works Dept.
200 W. Grove Avenue
Rantoul, IL 61866
(217) 892-2178



07/20/2016

NOTE: This product was prepared for informational
and general reference purposes. The Village of Rantoul
shall assume no liability for any error, omissions, or
inaccuracies in the information provided.

| 340 Indian Hills | | |
|------------------|---------------|-------------|
| Year | Copper (ug/L) | Lead (ug/L) |
| 2014 | 31 | 1 |
| 2011 | 21 | 1 |
| 2008 | 14 | 1 |

| 311 Indian Hills | | |
|------------------|---------------|-------------|
| Year | Copper (ug/L) | Lead (ug/L) |
| 2014 | 48 | 1 |
| 2011 | N/A | N/A |
| 2008 | N/A | N/A |

| 310 Woodland | | |
|--------------|---------------|-------------|
| Year | Copper (ug/L) | Lead (ug/L) |
| 2014 | 65 | 1.4 |
| 2011 | 87 | 1 |
| 2008 | 27 | 1 |

| 349 W. Champaign | | |
|------------------|---------------|-------------|
| Year | Copper (ug/L) | Lead (ug/L) |
| 2014 | 25 | 1 |
| 2011 | 17 | 1 |
| 2008 | 6 | 1 |

